

Excerpted from NFPA 1221 (2016 Edition):

Standard for Installation, Maintenance, and Use of Emergency Services Communications System

9.6.13.2 Dedicated Panel.

- (1) A dedicated monitoring panel shall be provided within the fire command center to annunciate the status of all RF emitting devices and system component locations. The monitoring panel shall provide visual and labeled indications of the following for each system component and RF emitting device:
 - (a) **Normal ac power**
 - (b) **Loss of normal ac power**
 - (c) **Battery charger failure**
 - (d) **Low battery capacity (to 70 percent depletion)**
 - (e) **Donor antenna malfunction**
 - (f) **Active RF emitting device malfunction**
 - (g) **System component malfunction**

- (2) The communications link between the dedicated monitoring panel and the two-way radio communications enhancement system must be monitored for integrity.

www.DASalert.com

NFPA-72, NFPA-1221 Public Safety DAS Annunciator System